

PUBLIC HEARING

March 22, 2004

6:50 p.m.

Present: Sup. Newlin; Council Members Ceretto, Johnson & Langlois; Town Atty. J. Leone; Dpty. Town Atty. Boniello; Dpty. Town Sup. Elgin; Finance Office E. Evert; Town Clerk C. Brandon; 5 Residents and 1 Press.

Absent: Councilman Kilmer.

The Supervisor opened the public hearing and asked that the Clerk read the notice.

NOTICE OF PUBLIC HEARING

LEGAL NOTICE IS HEREBY GIVEN that a Public Hearing will be held before the Town Board of the Town of Lewiston, New York on the 22nd day of March, 2004 at 6:45 p.m. at the Town Hall, 1375 Ridge Road, Town of Lewiston, to hear all interested parties and citizens for or against the adoption of a proposed amendment to Chapter 21, Sewers, Article 11, §21-7(F) of the Town Code, to read as follows.

In order to prevent groundwater from entering the town sanitary sewer system, all wyes and clean-out connections shall have an approved joint restraint. This approved joint restraint shall serve as protection from frost and other forces which may separate any section of pipe or piping from a riser, wye or clean-out connection. All riser sections of pipe or piping from the wye or clean-out connection shall extend not less than four inches (4.00") above the average finished grade and shall be sealed with an approved cap. The average finished grade shall be determined by measurements from a radius of five feet (5.00') from the riser of said wye and/or clean-out connections. Final determination of the riser elevation shall occur after all construction activity regarding the building sewer has been completed and the town or yard established.

All wyes installed in the town sanitary sewer system in front of each building shall have a six-inch outlet. Private laterals connected thereto may have either a six-inch or a four-inch inside diameter and must consist of one of the following: ductile iron pipe (DIP), polyvinyl chloride plastic pipe (PVC) SDR35 or solid-wall acrylonitrile/butadiene/styrene plastic pipe (ABS). Pipe shall be laid in a granular bed in accordance with the town's typical building sewer detail. Standard town construction details are referenced in the Code of the Town of Lewiston, New York Chapter 21C, Specifications for Public Improvements.

**Town Board of the Town of Lewiston
By Carol J. Brandon, Town Clerk
March 3, 2004**

The Supervisor asked if anyone wished to speak at this time. No one wished to.

Langlois MOVED that the Public Hearing be closed. Seconded by Johnson and carried 4-0.

Time: 6:53 p.m.

Respectfully submitted and transcribed by:

Carol J. Brandon
Town Clerk